

TEST REPORT

for

**Regupol America
33 Keystone Drive
Lebanon, PA 17042
Bill Devin/ 717-675-2198**

Impact Sound Transmission Test

ASTM E 492 – 09 / ASTM E 989 – 06

On

**6 Inch (152mm) Concrete Slab Overlaid with
Engineered Hardwood Flooring Adhered with Sikabond-T35 Adhesive over
Regupol Sonus HS1000, 10 mm Underlayment Adhered with Sikabond-T35
Adhesive With Suspended Gypsum Board Ceiling**

Report Number: NGC 7011095_R2


Assignment Number: G-709

Test Date: 08/10/2011


Report Approval Date: 09/12/2011

Reissue Date: 8/20/2014

Submitted by: _____


Andrew E. Heuer
Senior Test Engineer

Reviewed by: _____


Robert J. Menchetti
Director

The results reported above apply to specific samples submitted for measurement. No responsibility is assumed for performance of any other specimen. The laboratory's accreditation or any of its test reports in no way constitute or imply product certification, approval, or endorsement by NVLAP or any agent of the U.S. Government. This report may not be reproduced except in full, without written approval of the laboratory.

Revision Summary:

Date	SUMMARY
Approval Date: 9/12/2011	Original issue date. Original NGCTS report #: NGC 7011095
Reissue Date: 6/24/2014	Reissued Report #: NGC 7011095_R1 The report was reissued due to a client designated company name change.
Reissue Date: 8/20/2014	Reissue Report #: NGC 7011095_R2 The report was revised and reissued due to a client designate product name change and company name change.

The results reported above apply to specific samples submitted for measurement. No responsibility is assumed for performance of any other specimen. The laboratory's accreditation or any of its test reports in no way constitute or imply product certification, approval, or endorsement by NVLAP or any agent of the U.S. Government. This report may not be reproduced except in full, without written approval of the laboratory.

Report Number: NGC 7011095_R2

Test Method: This test method is in accordance with American Society for Testing and Materials Standard Test Method for Laboratory Measurement of Sound Transmission Through Floor-Ceiling Assemblies Using the Tapping Machine - Designation: E 492-09 / E 989-06.
The uncertainty limits of each tapping machine location met the precision requirements of section A1.4 of ASTM E 492-09.

Specimen Description: 6 inch (152mm) Concrete Slab including suspended grid 5/8 inch gypsum board ceiling system, overlaid with, according to client, Engineered wood flooring with Sikabond-T35 adhesive over Regupol Sonus HS1000, 10 mm underlayment adhered with Sikabond-T35 adhesive.

The test specimen was a floor-ceiling assembly consisting of the following:

- 1 layer of 13.1mm (0.515 in.) Hard Maple Select V Engineered Hardwood flooring. Samples were 127mm (5 in.) wide, by random length planks. Sample weight was 7.5 kg/m² (1.54 PSF).
- 1 layer of Sikabond-T35 adhesive. Sample was troweled on using client supplied P5 trowel.
- 1 layer of, according to client, Regupol Sonus HS1000, 10 mm underlayment. The underlayment was adhesively applied to the concrete with Sikabond-T35 adhesive. Measured thickness: 10.0 mm (0.395 in.) Measured weight: 7.7 kg/m² (1.58 PSF)
- 1 layer of Sikabond-T35 adhesive. Sample was troweled on using client supplied P5 trowel.
- 152.4mm (6 in.) thick reinforced concrete slab 366.2 kg/m² (75.0 PSF).
- 88.9mm (3-1/2 in.) fiberglass unfaced batt insulation. Sample weight was 0.78 kg/m² (0.16 PSF). The insulation was laid over the suspended grid system parallel with the main tee's.
- Gypsum board ceiling grid suspension system. System is comprised of main tees and cross tees. The main tees were placed 1219.2mm (48 in.) on center and the cross tees were placed 609.6mm (24 in.) on center. 16 gauge galvanized tie wire was used to attach the main tees to concrete anchors, located 1219.2mm (48 in.) o.c. along the longitudinal axis, suspending the grid 304.8mm (12 in.) below the concrete slab.
- 1 layer of 15.9mm (5/8 in.) Type X gypsum board. Sample was observed to be 15.9mm (0.628 in.) thick and weighed 11.2 kg/m² (2.3 PSF). The board was attached 304.8mm (12 in.) o.c. parallel to suspended grid suspension system mains, using 31.8mm (1.250 in.) Type S drywall screws. The board joints were taped.

The overall weight of the test assembly is 393.4 kg/m² (80.58 PSF).

The perimeter of the concrete slab was sealed with rubber gasketing and a sand filled trough. The test assembly is structurally isolated from the receiving room.

Test Floor Size: 3657.6mm x 4876.8mm (12 ft. x 16 ft.).

Conditioning: Adhesive cured for minimum of 24 hours. Concrete cured minimum of 28 days.

Test Results: The results of the tests are given on pages 4 and 5.

The results reported above apply to specific samples submitted for measurement. No responsibility is assumed for performance of any other specimen. The laboratory's accreditation or any of its test reports in no way constitute or imply product certification, approval, or endorsement by NVLAP or any agent of the U.S. Government. This report may not be reproduced except in full, without written approval of the laboratory.

Normalized impact sound pressure level						
Test: ASTM E 492 - 09 / ASTM E 989 - 06						
Test Report: NGC 7011095_R2					Date: 8/10/2011	
Specimen Size [m²]: 17.8					Page 4 of 5	
Source room				Receiving room		
Rm Temp [°C]: 19.5				Volume [m³]: 60		
Humidity [%]: 50				Rm Temp [°C]: 23		
				Humidity [%]: 48		
Impact Insulation Class IIC [dB]: 72						
Sum of Unfavorable Deviations [dB]: 31						
Max. Unfavorable Deviation [dB]: 8				at 100 Hz		
Frequency	L _n	L2	d	Corr.	u.Dev.	ΔL _n
[Hz]	[dB]	[dB]	[dB/s]	[dB]	[dB]	
100	48	51.1	32.1	-3.1	8	2.05
125	46	50.7	22.2	-4.7	6	2.70
160	47	52.4	18.2	-5.4	7	1.48
200	46	52.0	16.0	-6.0	6	1.18
250	44	49.9	17.0	-5.9	4	0.57
315	40	45.5	17.4	-5.5		0.52
400	37	44.3	17.9	-7.3		0.30
500	31	38.5	18.8	-7.5		0.44
630	32	38.9	20.8	-6.9		0.98
800	22	29.1	21.6	-7.1		0.28
1000	24	28.1	23.8	-4.1		0.14
1250	20	24.2	26.5	-4.2		0.24
1600	12	17.0	28.4	-5.0		0.74
2000	12	16.9	32.2	-4.9		0.65
2500	11	15.4	36.9	-4.4		0.57
3150	11	14.8	39.2	-3.8		0.99
4000	11	14.6	45.0	-3.6		1.35
5000	9	11.8	50.6	-2.8		1.03
L _n = Normalized Sound Pressure Level, dB L2 = Receiving Room Level, dB d = Decay Time, dB/second ΔL _n = Uncertainty for 95% Confidence Level						

The results reported above apply to specific samples submitted for measurement. No responsibility is assumed for performance of any other specimen. The laboratory's accreditation or any of its test reports in no way constitute or imply product certification, approval, or endorsement by NVLAP or any agent of the U.S. Government. This report may not be reproduced except in full, without written approval of the laboratory.

Normalized impact sound pressure level

Test: ASTM E 492 - 09 / ASTM E 989 - 06

Page 5 of 5


Test Report: NGC 7011095_R2

Test Date: 8/10/2011

Specimen Size [m²]: 17.8

Impact Insulation Class IIC [dB]: 72

Frequency [Hz]	L _n [dB]
100	48
125	46
160	47
200	46
250	44
315	40
400	37
500	31
630	32
800	22
1000	24
1250	20
1600	12
2000	12
2500	11
3150	11
4000	11
5000	9



* Due to high insulating value of specimen, background levels limit results at these frequencies.

L_n = Normalized Sound Pressure Level, dB

The results reported above apply to specific samples submitted for measurement. No responsibility is assumed for performance of any other specimen. The laboratory's accreditation or any of its test reports in no way constitute or imply product certification, approval, or endorsement by NVLAP or any agent of the U.S. Government. This report may not be reproduced except in full, without written approval of the laboratory.