


IIC
62

Assembly

- Laminate Flooring, 5/16" (8mm)
- Concrete Slab, 1-1/2" (38mm)
- Sonus Curve 17, 11/16" (17mm)
- OSB Wood Raft System, 3-5/8" (92mm)
- CLT, 5-3/16" (131mm)



Contact

REGUPOL America LLC
11 Ritter Way
Lebanon, Pennsylvania 17042
UNITED STATES OF AMERICA
www.regupol.com

Notes

Adjacent trades are only shown schematically and in parts. The applicability and other conditions or constraints need to be checked by the customer or user on their own responsibility. The technical data sheets, installation instructions and local conditions need to be considered.

Acoustical Test Assembly

Test Report no.: A1-008253-35SF

Test Report no.:

Drawn by: DLG

Test Date: 4.14.2016

Scale: N/A

DWG no.: 1