

STC
70

IIC
70

Δ IIC
42


Rw
70

Lnw
40

Δ Lw
38

Assembly

- Concrete, 4" (100mm)
- SoundPanel x4, 2-1/16" (53mm)
- Concrete, 5-1/2" (140mm)



Contact

REGUPOL America LLC
11 Ritter Way
Lebanon, Pennsylvania 17042
UNITED STATES OF AMERICA
www.regupol.com

Notes

Adjacent trades are only shown schematically and in parts. The applicability and other conditions or constraints need to be checked by the customer or user on their own responsibility. The technical data sheets, installation instructions and local conditions need to be considered.

Acoustical Test Assembly

Test Report no.: ES_25-H406-42822_E

Test Report no.:

Drawn by: DLG

Test Date: 3.28.2017

Scale: N/A

DWG no.: 1