


STC 71
IIC 72
 Δ IIC 43
Rw 71
L_{nw} 38
 Δ L_w 40

Assembly

- Concrete, 4" (100mm)
- SoundPanel x4, 2-5/8" (66mm)
- Concrete, 5-1/2" (140mm)



Contact

REGUPOL America LLC
 11 Ritter Way
 Lebanon, Pennsylvania 17042
 UNITED STATES OF AMERICA
 www.regupol.com

Notes

Adjacent trades are only shown schematically and in parts. The applicability and other conditions or constraints need to be checked by the customer or user on their own responsibility. The technical data sheets, installation instructions and local conditions need to be considered.

Acoustical Test Assembly

Test Report no.: ES_25-H408-42822_E
 Test Report no.:
 Drawn by: DLG
 Test Date: 3.28.2017
 Scale: N/A DWG no.: 1