


STC
59

IIC
65

Assembly

- Concrete Slab, 4" (102mm)
- Regupol Vibration 200, 1-5/16" (34mm)
- Concrete Slab, 6" (152mm)



Contact

REGUPOL America LLC
11 Ritter Way
Lebanon, Pennsylvania 17042
UNITED STATES OF AMERICA
www.regupol.com

Notes

Adjacent trades are only shown schematically and in parts. The applicability and other conditions or constraints need to be checked by the customer or user on their own responsibility. The technical data sheets, installation instructions and local conditions need to be considered.

Acoustical Test Assembly

Test Report no.: NGC 5016054

Test Report no.: NGC 7016081

Drawn by: DLG

Test Date: 5.9.2016

Scale: N/A DWG no.: 1